



Fire, smoke, fire/smoke damper matrix 4E

See attached page for completion information

IDPH number _____

Damper ID#	System identification	Type	New/ existing	Static/ dynamic	Size	UL classification no. Example: (E12345)	Location	Fusible link temp. rating	Access door location	Operation certified by - date and initials

I certify that all fire, smoke, and fire/smoke dampers, existing and new, serving new construction and/or renovated spaces have been tested, inspected and are operational per NFPA-90

Installer's name and company

Signature

Date

Page ____ of ____



Damper ID# - Facility's unique damper identifier

System Identification - AHU # - Supply (S), AHU # - Return (R), Exhaust (E)

Type - Fire (F), Smoke (S), Combination Fire/Smoke (F/S), Ceiling (C), AHU Isolation (I)

Static (S) or Dynamic (D)

UL Classification # - Example: E12345 - (555-555S-555C is the UL standard by which dampers are classified)

Location - Floor and room number

Access door location - Floor and room number

If multiple pages are submitted, the signature is required only on the last page.